

State of California
Department of Public Health

Water Treatment Device
Certificate Number

03 - 1569

Date Issued: May 22, 2008

Trademark/Model Designation

Replacement Elements

Multi-Pure MP880SB	CB11As
Multi-Pure MP880SC	CB11As
Multi-Pure MP880SI	CB11As
Multi-Pure MP880EL(960 gallons)	CB11As

Manufacturer: Multi-Pure Drinking Water Systems

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts
Turbidity

Inorganic/Radiological Contaminants

Arsenic V (50 ppb)
Asbestos
Lead
Mercury

Organic Contaminants

Chlordane
MTBE
PCB
Toxaphene
VOCs by chloroform surrogate

Rated Service Capacity: 600 gallons

Rated Service Flow: 1.0 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

¹ Claims for arsenic reduction shall only be made on water supplies maintaining detectable residual free chlorine at the system inlet. Water systems using an in-line chlorinator should provide a minimum of 1 minute chlorine contact time before the filtration system.